


Munsie Enterprises Inc - CCC 056809 (Steven Munsie)



- Mounting the overflow scupper flush with the deck height by parapet on this illustration would be 4" above primary drain system
- Mounting "2"-4" above the roof deck" as per FBC 1503.4.21 would allow 2"-4" more rain water to accumulate before overflow scuppers would be useful.