



**Informal Interpretation Report  
Number 4341**



**Date** May 04, 2025

**Edition** 2001

**Section** 910

**Question:**

Is it the intent of Section 910 to require smoke and heat vents to be installed in all buildings with high-piled combustible storage and/or buildings with ESFR sprinkler systems?

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.