



## Informal Interpretation Report Number 6143



**Date** May 13, 2009

**Edition** 2007

**Section** R305.1

### **Question:**

Is it the intent of Florida Building Code - Residential section R305.1, Exception 4, to include the tank portion of a water closet as an element of a "fixture" that requires a minimum 6'-8" ceiling height above it?

### **Answer**

Yes. The minimum ceiling height must be provided over the entire fixture. Florida Building Code - Residential section R305.1, Exception # 4 states that "bathrooms shall have a minimum ceiling height of 6' 8" over the fixture and at the front clearance area for fixtures as shown in Figure 307.1".

### **Commentary:**

Exception # 4 defines the required minimum ceiling height over toilet, bath and shower fixtures. This exception allows a sloped ceiling over toilet, bath or shower fixtures provided the minimum ceiling height of 6' 8" is maintained over the fixture and at the front clearance.

---

### **Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.