



**Informal Interpretation Report
Number 6533**



Date June 14, 2010

Edition 2007

Section 210.52(E)(3)

Question:

Is it the intent of the Florida Building Commission, April 7, 2010 Meeting, Summary Report regarding FBC section 301.2.1.1.2, Sunrooms - receptacle requirements, to override the 2008 NEC section 210.52(E)(3) regarding the required receptacle outlet for Balconies, Decks, and Porches?

Answer:

It is not a question of "overriding" the NEC. AAMA 2100 is more specific than NFPA 70 with regard to the definition of sunrooms and the placement of receptacle outlets, and therefore, in accordance with Section 102.1 of the Florida Building Code, Building the provisions of AAMA 2100 prevail over NFPA 70.

On 06/14/2010 at 2:16 PM

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.