



**Informal Interpretation Report
Number 6582**



Date July 09, 2010

Edition 2007

Section 423.10.2.4

Question:

Is it the intent of Florida Building Code - Building Section 423.10.2.4 to require 42" high guardrails on "temporary" relocatable ramps where the vertical drop exceeds 18"?

Answer

Yes. Florida Building Code - Building Section 423.10.2.4 requires 42" high guardrails on "temporary" relocatable ramps where the vertical drop exceeds 18".

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.