



**Informal Interpretation Report
Number 6601**



Date August 19, 2010

Edition 2007

Section 1911

Question:

Is it the intent of Florida Building Code - Building Section 1911 to require post-installed anchors to be designed per the requirements of ACI 318, Appendix D and to also have a current product approval?

Answer

No.

Commentary:

If the manufacturer's published literature is based on ACI 318 Appendix D. Comment: There are two acceptable methods for product approval in HVHZ. One, Miami-Dade County NOA for HVHZ, and the other one optional state approval for specific use in HVHZ.

This response does not intend to apply directly to the "comments" section as submitted. The question proposed is answered herein only.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.