



**Informal Interpretation Report
Number 6614**



Date September 01, 2010

Edition 2007

Section 3002.4

Question:

Is it the intent of Chapter 30 to delineate where elevators are required or simply describe the particulars of type, installation, and maintenance of an otherwise required elevator?

Answer

Where elevators are provided, they must meet the criteria outlined in 3002.4

Commentary:

One area in the code that would "require" an elevator or equivalent facilitation would be the vertical accessibility requirements found in chapter-11. Further, Florida Statute 399.035(2) states, "Any building that is more than three stories high or in which the vertical distance between the bottom terminal landing and the top terminal landing exceeds 25 feet must be constructed to contain at least one passenger elevator that is operational and will accommodate an ambulance stretcher 76 inches long and 24 inches wide in the horizontal position."

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.