



**Informal Interpretation Report
Number 6623**



Date September 04, 2010

Edition 2007

Section 1030.12

Question:

Is it the intent of FBC-Building section 1030.12 to supersede the travel distance requirements of sections 1030.11.2.1 and 1030.11.2.2? Is it possible that one of these sections is an error?

Answer

The answer to the question is "yes." In the event of a conflict, the most exacting requirement, 1030.12, shall apply.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.