



**Informal Interpretation Report
Number 6627**



Date September 20, 2010

Edition 2007

Section 230.2(D)

Question:

Is it the intent of NEC section 230.2(D) to allow a second electrical service on a dwelling unit if the utility charges at a different rate (i.e. commercial vs. residential)?

Answer

Yes.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.