



**Informal Interpretation Report
Number 6628**



Date September 20, 2010

Edition 2007

Section Table 2903.2b note d

Question:

Is it the intent of Table 2903.2b note "d" to require the primary backflow device at the meter to be the same size as the water service piping run to the dwelling.

Answer

Yes, it is the intent of the footnote that the backflow assembly must be the same size as the water service. Meter size is not regulated by the code and may be smaller than the code required water service size.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.