



**Informal Interpretation Report
Number 6631**



Date September 20, 2010

Edition 2007

Section 3103.1

Question:

Is it the intent of section R3103.1 that vent pipes terminate at least 6 inches from torch down or the top of barrel tiles?

Answer

The intent of R3103.1 is that the vent pipe shall terminate at least 6 inches above the finished (surface of the) roof.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.