



**Informal Interpretation Report
Number 6637**



Date September 20, 2010

Edition 2007

Section 1015.2

Question:

Is it the intent of Section 1015.2 that all exits and exit access doorways be arranged in accordance with 1015.2.1 and 1015.2.2 including accessible exits?

Answer

No. If the required exits or exit access meet the separation requirements of the code all additional exits may be placed anywhere.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.