



**Informal Interpretation Report  
Number 6642**



**Date** March 22, 2011

**Edition** 2007

**Section** 1507.2.10

**Question:**

Is it the intent of Section 1507.2.10 specifically TABLE 1507.2.10 to allow the installation of asphalt shingles in all wind zones (100 up to 150 mph), although the asphalt shingle product approval is only valid up to 110 mph? (TAS 107 and ASTM 3161 Class F are tests rated to 110 mph)

**Answer:**

Yes, if the shingle is classified as ASTM D3161 Class F, TAS 107 or ASTM D 7158 Class H and so noted on the shingle wrapper they may be installed in all wind zones.

On 03/22/2011 at 8:38 AM

**Commentary:**

Caution should be observed of shingles sold without wrappers. They do not comply with anything.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.