



**Informal Interpretation Report
Number 6653**



Date March 22, 2011

Edition 2007

Section 606.5

Question:

Is it the intent of this section to allow impact glass (protected) doors used to enclose balconies to be the impact protection for the existing building interior openings in HVHZ?

Answer

YES to the question.

Commentary:

NO to the comment.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.