



**Informal Interpretation Report
Number 6655**



Date March 29, 2011

Edition 2007

Section 410.130(G)

Question:

Is it the intent of the Florida Existing Building Code that existing double ended fluorescent luminaires in a level 1,2,or 3 alteration that are relocated comply with the disconnecting means required by NEC 410.130(G)?

Answer

NO, unless the existing fixtures were being replaced or upgraded with new ballasts.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.