



**Informal Interpretation Report  
Number 6666**



**Date** March 30, 2011

**Edition** 2007

**Section** 1522

**Question:**

Is it the intent of Section 1522.3.4 to be applied to an electrical conduit that is found concealed within the roof insulation while a tear-off is being performed?

**Answer**

No. 1522.3.4 states "on the roof" the conduit described is "in the roof" and that code section would not apply.

**Commentary:**

None.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.