



**Informal Interpretation Report  
Number 6671**



**Date** March 30, 2011

**Edition** 2007

**Section** 602.1

**Question:**

Is it the intent of the code that the structure actually have running water in the house if the house is being utilized for human occupancy or habitation. How is "shall be provided" interpreted?

**Answer**

Yes, the intent of "shall be provided" is that potable water supply is available for use at all times to the fixtures at the pressure and amount required by code to every building intended to be occupied.

**Commentary:**

None.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.