



**Informal Interpretation Report
Number 6677**



Date June 02, 2011

Edition 2007

Section Table 403.1

Question:

Is it the intent of code for private clubhouse of 17,000 sf that has a golf shop of 600 sf to have facilities for 1 men and 1 women toilet fixture in the building count or add the total sf together with the correct personnel capacity.

Answer

Because the golf shop is less than 10% of the main structure it is an accessory to the main occupancy, the 17000sqft assembly occupancy is used for the fixture count.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.