



**Informal Interpretation Report
Number 6679**



Date April 07, 2011

Edition 2007

Section 419.1

Question:

Is it the intent of section 419.1 to prohibit the use of waterless urinals since the ASME approval listed for the urinal is ASME A112.19.19 and not ASME A112.19.2M

Answer

The answer to the question is, "NO."

The Code states that Urinals shall conform to ANSI Z124.9, ASME A112.19.2M, CSA B45.1 or CSA B45.5.

Some waterless urinals do conform to ANSI Z124.9 and would therefore be acceptable.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.