



**Informal Interpretation Report
Number 6680**



Date April 07, 2011

Edition 2007

Section R301.2.1.2

Question:

Is it the intent of the exception to section R301.2.1.2 to require permanently attached hardware for the pre-drilled plywood to be attached over the openings in a building for wind borne debris protection?

Answer

Yes.

Commentary:

That was the intent stated by the proponent of the modification.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.