



**Informal Interpretation Report
Number 6682**



Date April 07, 2011

Edition 2007

Section 2406

Question:

Is it the intent of 2406 to prevent the use of wire glazing properly labeled and rated by manufacturer as safety glazing to be used in "hazardous location"?

Answer

If the wire glass meets the requirements of CPSC 16 CFR 1201 then it can be used.

Commentary:

CPSC 16 CFR 1201 has an exception for wired glass in doors.
Many wired glass products do not meet the standard.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.