



**Informal Interpretation Report
Number 6688**



Date April 07, 2011

Edition 2007

Section R4101.17.1.9

Question:

Is it the intent of R4101.17.1.9 to allow either
battery powered or hard wired pool exit alarms?

Answer

Yes as long as it complies with UL 2017.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.