



**Informal Interpretation Report
Number 6699**



Date April 19, 2011

Edition 2007

Section 514.2

Question:

Is it the intent of FBC Mechanical 514.2 to prohibit all hazardous exhaust (covered in Section 510) from being a source for energy recovery systems?

Answer

Yes.

Commentary:

The code allows the local Building Official to consider "Alternative materials, design and methods of construction and equipment" in accordance with FBC 104.11.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.