



**Informal Interpretation Report
Number 6707**



Date April 21, 2011

Edition 2007

Section 423.16.1.2

Question:

In it the intent that if a state funded educational school that under goes a remodeling in a classroom or building. Only those remodeled classroom(s) are required to have the path of travel to the nearest toilet facility shall not exceed a distance of 200 feet.

Answer

Yes, unless the remodeled spaces includes a new group toilet room. In that case the 200 feet rule would apply as much as possible for the existing configuration of the building(s).

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.