



**Informal Interpretation Report
Number 6735**



Date December 01, 2011

Edition 2007

Section 1025.6.2.3

Question:

Is it the intent of 1025.6.2.3 exception (1) to override the provision of 903.2.1.4 exception where the floor playing surface is a story below the main entrance and exit discharges.

Answer

No. The case stated above does not meet all of the requirements provided in the exception to 903.2.1.4. The arena floor is required to be on the same level as the level of exit discharge. In this case the arena floor is below the level of exit discharge.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.