



**Informal Interpretation Report
Number 6746**



Date May 26, 2011

Edition 2007

Section 504.6

Question:

Is it the intent of 504.6 number 7 to require the readily observable location be located inside the building?

Answer

504.6 #7 Requires that the discharge shall be readily observable by the occupants of the building. It does not matter if the discharge is inside or outside the building.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.