



**Informal Interpretation Report
Number 6760**



Date October 26, 2011

Edition 2007

Section 1010.1 Exception (1)

Question:

Is it the intent of Exception (1) under 1010.1 RAMPS to disallow the enforcement of 1010.10, GUARDS, on accessible ramps over 30 inches in height? Note: Chapter 11 has no requirement for GUARDS on curb ramps over 30 inches above grade.

Answer

No.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.