



**Informal Interpretation Report
Number 6762**



Date June 16, 2011

Edition 2007

Section 1010

Question:

Is it the intent of Exception (1) under Section 1010.1 RAMPS / SCOPE to disallow the use of Section 1010.10 GUARDS and 1013 GUARDS on ramps that are part of an accessible route?

Answer

No.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.