



**Informal Interpretation Report
Number 6770**



Date June 16, 2011

Edition 2007

Section 907.9

Question:

Is it the intent of 907.9 and specifically 907.9.1.1 to require notification devices in a Group M occupancy that does not meet the threshold requirement for a fire alarm system in 907.2.7?

Answer

No. 907.2 only requires notification devices when a fire alarm system is required under the 907.2 subsections. If no fire alarm system is required, no notification devices are required.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.