



**Informal Interpretation Report
Number 6776**



Date June 16, 2011

Edition 2007

Section 424.2.17.1.9 , #1

Question:

Is it the intent of Section 424.2.17.1.9, #1 to allow the use of an exit alarm unit on doors and/or windows that has a switch or keypad built in that can turn the alarm completely off?

Answer

Only if it meets all the limitations stated in
424.2.17.1.9.1

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.