



**Informal Interpretation Report  
Number 6783**



**Date** June 23, 2011

**Edition** 2007

**Section** 405.3.1

**Question:**

Is it the intent of this section that stall dimension for a standard urinal is to be 30 inches wide?

**Answer**

Yes, 405.3.1 states that a urinal must be 15" from its center to any obstruction. 30" total clear space.

**Commentary:**

30 inches is a minimum dimension.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.