



**Informal Interpretation Report
Number 6789**



Date July 28, 2011

Edition 2007

Section 419.3.12.1

Question:

Is it the intent of of this section to require connection of a 400 cfm exhaust fan, serving only one room, to the fire aalarm system for the purpose of stopping the fan upon activation of the fire alarm system?

Answer

No.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.