



**Informal Interpretation Report
Number 6799**



Date July 20, 2011

Edition 2007

Section 903.3.1.2

Question:

Is it the intent of this section to require the breezeway to be sprinklered in a 3 story garden apartment building, Group R-2, Type V-A construction.

Answer

Yes - as required by NFPA 13R.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.