



**Informal Interpretation Report
Number 6807**



Date August 03, 2011

Edition 2007

Section 417.5.2

Question:

Is it the intent of Section 417.5.2 to not except a manufactured cultured marble shower base with a factory recommended drain connection installed, from being an approved prefabricated receptor?

Answer

NO, a prefabricated receptor such as a marble receptor would be permitted as long as the prefabricated receptor meets the requirements of 417.1

Commentary:

none.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.