



**Informal Interpretation Report
Number 6823**



Date August 25, 2011

Edition 2007

Section 403.7.2

Question:

Is it the intent of section 403.7.2 to not allow a floor mounted mop sink inside of a unisex toilet room?

Answer

YES. The intent of that section IS to NOT ALLOW a mop sink inside the unisex room. Toilets, lavs, and urinals only.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.