



**Informal Interpretation Report  
Number 6827**



**Date** August 25, 2011

**Edition** 2007

**Section** 403.2

**Question:**

We are Designing a multi-tenant warehouse building that consist of small storage bays with the following areas. 1,130 sf storage 126 sf office 58 sf single station toilet room for a total of 1,256 sf. Is it the intent of the code to require separate facilities where such a small area exists and installing the separate facilities would take up approximately 10% of the entire bay.

**Answer**

Yes, unless one of the exceptions in 403.2 applies.

**Commentary:**

Your example appears to be a storage occupancy with an accessory business occupancy. if so this would not meet one of the exceptions.

---

**Notice:**

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.