



**Informal Interpretation Report
Number 6833**



Date October 03, 2011

Edition 2007

Section 311.2

Question:

Is it the intent of section 311.2 to include a truck maintenance building that is part of a materials recovery facility?

Answer

A motor vehicle repair garage is clearly a S-1 occupancy, not manufacturing. It appears from the question the structure is a separate building, therefore again a S-1.

Commentary:

Each building and/or occupancy must be addressed separately.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.