



**Informal Interpretation Report
Number 6841**



Date October 26, 2011

Edition 2007

Section 1008.1.4

Question:

Is it the intent of Section 1008.1.4 to provide a level landing (max. 1/2" difference) on either side of a door leading from an exterior walkway to the inside of a small pump house (non occupiable) building?

Answer

As noted in 1008.1 only Means of Egress doors are governed by Section 1008. This space is not an Occupiable space this space is an equipment/containment room that only service personnel will use.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.