



**Informal Interpretation Report
Number 6842**



Date October 26, 2011

Edition 2001

Section 1403.1.4

Question:

Is it the intent of FBCB 2001 Section 1403.1.4 to require flashing at a 29" x 48" opening in a four-inch concrete wall with an exterior insulation and finish system?

Answer

Yes.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.