



**Informal Interpretation Report
Number 6851**



Date December 01, 2011

Edition 2007

Section 706.2

Question:

Is it the intent of 706.2 to prohibit the use to "inside the pipe" closet flanges such as the Oatey #43539 which slides inside of 4" sch. 40 DWV, which has a compress joint tightened bt (3) set screws set into a ledge inside the flange?

Answer

Closet flanges with ledges such as screw tops would be prohibited by this section. Inside closet flanges would be prohibited on 3" pipe because it would decrease the size to less than 3".

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.