



**Informal Interpretation Report
Number 6856**



Date November 01, 2011

Edition 2007

Section Table 403.1

Question:

Is it the intent of Item #8 Storage to require a bathtub/shower at 1 per 1,000?

Answer

No. T-403.1 of the 2007 Plumbing Code in row #8 under the column heading "BATHTUBS/ SHOWERS" it states "see section 411", section 411 is "EMERGENCY SHOWERS AND EYEWASH STATIONS".

Commentary:

In row #8 under the "DRINKING FOUNTAIN" column it states "see 410.1" which is "DRINKING FOUNTAINS".

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.