



**Informal Interpretation Report
Number 6858**



Date November 01, 2011

Edition 2007

Section 507

Question:

Is it the intent of the code to allow one story Group M buildings that meet the requirements for unlimited area buildings to be constructed using Type VB construction?

Answer

No. section 507.3 specifically states that the unlimited area application is for buildings "of other than Type V construction."

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.