



**Informal Interpretation Report
Number 6863**



Date December 01, 2011

Edition 2007

Section T403.1

Question:

Is it the intent of Section 403.2, to require separate facilities for an Educational/Daycare Use Classification with an occupant load of 10?

Answer

Yes.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.