



**Informal Interpretation Report
Number 6884**



Date January 24, 2012

Edition 2007

Section 1003.3

Question:

Is it the intent of section 1003.3 to not allow concrete grease interceptors if they do not meet the requirements of ASME A112.14.3 or PDI G101?

Answer

The current wording of this section does in fact prohibit the use of concrete tanks that do not meet the appropriate standard listed in this section for systems discharging to PUBLIC SEWER.

However, an exception has been added to the 2010 FPC which states that interceptors that are designed to comply with Rule 64 E-6 of Florida Administrative code do not have to comply with the ASME or PDI standards.

Commentary:

In accordance with 1003.5 Outdoor Grease interceptors for ONSITE sewage treatment and disposal systems appear to be allowed.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.