



**Informal Interpretation Report
Number 6923**



Date March 08, 2012

Edition 2010

Section 1102.6

Question:

Is it the intent of 1102.6, by referencing ASME A112.21.2M-1983, to prohibit PVC or ABS roof drains in Florida?

Answer

Unfortunately the 1983 Edition of ASME A112.21.2M is the edition adopted by the 2010 FBCP. The standard is no longer adopted in the IPC 2012; A112.6.4-2003 is adopted there.

The options available in FLorida are:

1. Comply with standard as adopted. 2. Request approval from the Building Official to use an alternate, equivalent material or method per FBC Building 104.11. 3. Request a determination of equivalency for the updated re-designated standard from the Florida Building Commission.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.