



**Informal Interpretation Report
Number 6935**



Date March 20, 2012

Edition 2007

Section 106.3

Question:

Is it the intent of of section 106.3 to allow a Building Official not certified pursuant to FS633.081(Firesafety inspector) to do the required (per FS 553.79(2)) Firesafety plan review before issuing a permit.

Answer

No. For firesafety plans designed in accordance with the Florida Fire Prevention Code, review is required to be conducted by a fire safety inspector certified in accordance with 633.081.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.