



**Informal Interpretation Report
Number 6964**



Date April 26, 2012

Edition 2010

Section 403.6.1.1

Question:

Is it the intent of the Code to have dealers/contractors submit documentation of manufacturer's expanded ratings (total and sensible capacities along with design CFM) along with their permit application?

Answer

Yes. FBC-EC Section 103.2.2 requires the construction documents to include "mechanical system design criteria; mechanical and service water heating system and equipment types, sizes and efficiencies..."

Commentary:

Applicants must submit whatever the Building Official deems necessary to confirm Code Compliance, per FBC 107.3.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.