



**Informal Interpretation Report
Number 6972**



Date April 26, 2012

Edition 2007

Section 1607.7.1.3

Question:

Is it the intent of Section 1607.7.1.3 to be used in all guardrail designs inclusive of those located in High Velocity Hurricane Zones?

Answer

No. The section does not apply in the HVHZ.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.