



**Informal Interpretation Report
Number 6987**



Date April 30, 2012

Edition 2010

Section 419.1.5

Question:

Is it the intent of this section that whatever FBC generation (2007, 2010, etc.) code was applied to the project when it was reviewed by AHCA shall be the same generation code used by the local municipality when they review the project?

Answer

AHCA review as referred to in 419.1.5, is only applicable for state licensure purposes by that agency. Building Code compliance would be determined by date of application and the code under which the permit was applied for, regardless of when AHCA did their licensure review.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.