



**Informal Interpretation Report
Number 7019**



Date September 22, 2026

Edition 2004

Section 308

Question:

Is it the intent of section 308 to require a
permit to replace hangers

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.